

Gaming the Refurbishment of a Hospital District using EU Streamer methods

The Rotherham
NHS Foundation Trust



Gaming Energy Refurbishment

- Nick Nisbet AEC3; nn@aec3.com,
- Martin Aizlewood TRFT; Martin.Aizlewood@rothgen.nhs.uk,
- John Cartwright TRFT; John.Cartwright@rothgen.nhs.uk
- Bob Wakelam AEC3; bw@aec3.com





EU STREAMER GOALS

Main aim: 50% reduced energy use and CO₂ emission of healthcare districts in 10 years

Achievements:

- Create generic semantic BIM+GIS typology models of Energy-efficient Buildings in healthcare districts
- Create a framework for BEM (Building Energy Model) lifecycle model inter-connecting BIM, BAM, BOOM
- Create a design decision-support tool as an interactive tool which accommodates: BIM+GIS models; KPIs for energy, life-cycle cost, functional quality; and stakeholder requirements




EU STREAMER OUTPUTS


- Semantic labelling methodology
- KPI tools (energy – quality – cost)
- *Design configurator – design validator*
- *Design rules (rooms – MEP – façade technology)*
- Data requirements checking
- Participatory design process
- Dashboard (decision support tool)




EU STREAMER DESIGN PROCESS



EU STREAMER labelling




OFFICE




HOTEL



INDUSTRY





HOT FLOOR





Introduction

- TRF has been reducing its energy bill for a decade
- TRF is currently obtaining electrical and thermal data for the test areas on a monthly basis




- Attention is now focussing on more local and specific refurbishment and upgrades



Progressive improvement

t CO₂




NHS ESTATES AND FACILITIES DASHBOARD 2014-15

CODE	RFR	TRUST NAME
------	-----	------------

THE ROTHERHAM NHS FOUNDATION TRUST

TRUST OVERVIEW				
Organisation type	ACUTE - MEDIUM			
Commissioning region	NORTH OF ENGLAND			
		2014-15	2013-14	
Total occupied floor area	m2	77,404	76,998	
Total estates and facilities running costs	£	14,653,529	16,404,280	
Potential total E & F running cost saving by moving to the trust type median	£	0	0	
Potential targeted E & F running cost savings from individual cost elements	£	127,976	551,916	
Potential cost savings from improved utilisation of space	£	To be confirmed		
% of occupied floor area operated under a PFI contract	%	0%	not collected	
% of occupied floor area under direct NHS management	%	100%	not collected	
E & F running cost of floor area operated under a PFI contract	£/m2	0.00	not collected	
E & F running cost of floor area under direct NHS management	£/m2	189.31	not collected	

METRICS SOURCED FROM NATIONAL DATA				
Domain 1 - Efficiency - Cost		TRUST METRIC		
		2014-15	Trend	2013-14
Total estates and facilities running / ATC	£ 1,000 / ATC	62.56	↓	64.7%
Total estates and facilities running costs	£ / m2	189.31	↓	213.08
Total Hard Facilities Management costs	£ 1,000 / ATC	27.55	↓	27.22
Energy costs	£ / Units	0.04	↓	0.04
Building and engineering maintenance	£ / m2	13.60	↓	35.87
Portering	£ / m2	12.22	n/a	not collected
Water and sewage costs	£ / m2	3.11	↓	3.38
Waste costs	£ / tonnes	245.63	↑	262.00
Total Soft Facilities Management costs	£ 1,000 / ATC	27.52	↑	27.52
Laundry and linen costs	£ / item	0.38	↑	0.35
Food costs	£ / meal	3.11	↑	2.99
Cleaning costs	£ / m2	12.22	↑	35.11



METRICS SCORING METHODOLOGY	
Quartile 1	Blue
Quartile 2	Green
Quartile 3	Amber
Quartile 4	Red

Domain 2 - Effectiveness - Productivity		2014-15	Trend	2013-14
Occupied Floor Area - ATC	1,000 m2 / ATC	0.33	↑	0.30
Amount of utilised space	%	97.2%	↑	96.8%
Amount of non-clinical space	%	34.2%	↑	31.0%
Total income earned per area	£ / m2	11.95	↑	2.058
Estates and facilities staff sickness absence	%	5.2%	↓	5.2%
Amount of energy used	Units / m2	498.96	↓	569.81
Portering	Beds/WTE	13.71	n/a	not collected
Waste - ATC	ATC ratio*	4.7	↑	4.05
Laundry and linen - ATC	ATC ratio*	7.33	↑	6.10
Food service productivity	Meals / Beds / Day	3.69	↓	3.28
Cleaning productivity	m2/WTE	945	↓	604

Domain 3 - Safety		2014-15	Trend	2013-14
Reported Critical Infrastructure (CIR)/Area	£/m2	58.35	↑	61.35
Reported Critical Infrastructure Risk	£	4,722,235	↑	3,944,508
Fires recorded	No.	2	↓	3
False Alarms	No.	45	↓	60
Number of people injured resulting from falls	No.	0	→	0
Number of patients sustaining injuries requiring evacuation	No.	0	→	0

Domain 4a - Quality - Patient Experience		2014-15	Trend	2013-14
Condition, Appearance and Maintenance	%	85.10%	↓	91.08%
Cleanliness	%	96.63%	↓	94.84%
Food	%	80.29%	↓	83.28%
Privacy, Dignity, Wellbeing	%	76.01%	↓	62.71%
Condition, Appearance and Maintenance	%	85.10%	↓	91.08%
Dementia	%	59.72%	n/a	not collected

Domain 4b - Quality - Infrastructure		2014-15	Trend	2013-14
Total reported backlog maintenance	£/m2	79.32	↓	96.02
Amount of functionally suitable space	%	96.11%	↑	99.59%
Single bedded rooms	%	24.8%	↓	28.9%
CO2 emissions	kg/m2	96.62	↓	134.83

Domain 5 - Organisation Governance Processes		2014-15	Trend	2013-14
Capital investment required to eliminate CIR	£	4,235,375	↓	1,066,485
Capital investment required to eliminate backlog	£	6,137,539	↓	8,627,578
Capital spend as % of NBV of land and buildings	%	3.8%	↑	0.7%
Retail Income	£/m2	45.61	n/a	not collected

2014-15 QUANTILES FOR ACUTE - MEDIUM				
Lowest	Lower Quartile	Median	Upper Quartile	Highest
45.17	68.55	94.68	119.54	243.59
115.44	210.60	301.16	396.09	678.81
6.76	17.80	23.70	30.69	59.12
0.03	0.05	0.06	0.07	0.11
0.00	22.73	27.25	36.17	63.70
6.31	12.47	14.81	17.87	24.13
1.10	2.87	3.48	4.33	7.86
62.99	203.43	227.09	288.26	640.98
9.20	30.85	39.10	48.15	72.52
0.16	0.29	0.31	0.43	4.87
2.10	3.17	3.92	4.83	11.20
14.40	31.26	39.50	45.70	89.27

Lowest	Lower Quartile	Median	Upper Quartile	Highest
0.18	0.26	0.31	0.38	0.51
63.8%	96.2%	97.9%	99.9%	100.0%
17.2%	34.3%	41.1%	45.7%	52.8%
1,917	2,592	2,974	3,443	5,127
0.0%	4.5%	5.2%	6.1%	7.4%
242.39	372.29	464.01	525.36	828.42
5.66	8.88	11.24	14.08	19.43
2.52	4.33	4.77	5.71	10.95
1.71	8.22	8.87	10.45	14.95
0.44	2.02	2.68	2.96	4.09
405	530	624	735	928

Lowest	Lower Quartile	Median	Upper Quartile	Highest
0.00	12.84	79.22	155.84	429.36
0	1,762,705	6,847,959	13,741,583	36,475,939
0	0	2	3	21
10	50	68	82	161
0	0	0	0	1
0	0	0	0	0


Lowest	Lower Quartile	Median	Upper Quartile	Highest
77.07%	82.80%	89.08%	94.01%	99.56%
90.64%	95.24%	97.60%	99.11%	100.00%
77.71%	84.52%	87.61%	91.18%	96.87%
75.36%	81.83%	85.71%	89.10%	98.24%
77.07%	82.80%	89.08%	94.01%	99.56%
49.31%	66.79%	72.64%	81.28%	92.04%

Lowest	Lower Quartile	Median	Upper Quartile	Highest
0.00	70.28	211.19	340.56	581.65
44.05%	89.53%	99.04%	100.00%	100.00%
11.6%	20.0%	27.7%	53.3%	53.3%
46.21	100.07	112.61	139.63	199.66

Lowest	Lower Quartile	Median	Upper Quartile	Highest
0	1,762,705	6,847,959	13,741,583	36,475,939
0	6,443,458	19,942,998	32,994,420	59,120,000
0.1%	2.0%	3.8%	5.5%	36.0%
0.00	180.58	405.66	874.69	6093.75



EU STREAMER REFURBISHMENT PROCESS



Rotherham Hospital



- Block model
 - Blocks and floors
 - Geo-location and rotation
 - Topography
 - Map
- Departments
 - Areas and volumes
- Zone and System model
 - Two zones (OPD and WB6), spaces, floors
 - attributes
 - key groupings
 - Systems, component, type
 - fixed
 - options
- Meter model
 - systems, component, type
 - annual estimated consumption
 - served zones
 - sharing cross factors

TRF RH1 Federation



Multiple sub-models
COBie format


	A	D	E	F	G	H	I				J	K	L	M	N
	Name	Category	ApprovalBy	Stage	SheetName	RowName	Directory				File	ExtSystem	ExtObject	ExtIdentifier	Description
1															
2	TRF_RH1_floors	Closeout Submit	ifcReferen	Submitted	Facility	TRF_RH1	C:\Users\nick\Documents\My Projects\EU Streamer\WP7\models\TRF_RH1_floors_floor.ifcxml				n/a	AEC3 UK B ifcDocumen	n/a	TRF_RH1_floors	
3	TRF_RH1_zones	Closeout Submit	ifcReferen	Submitted	Facility	TRF_RH1	C:\Users\nick\Documents\My Projects\EU Streamer\WP7\models\TRF_RH1_zones_zone.ifcxml				n/a	AEC3 UK B ifcDocumen	n/a	TRF_RH1_zones	
4	TRF_RH1_storeys	Closeout Submit	ifcReferen	Submitted	Facility	TRF_RH1	C:\Users\nick\Documents\My Projects\EU Streamer\WP7\models\TRF_RH1_storeys_storey.ifcxml				n/a	AEC3 UK B ifcDocumen	n/a	TRF_RH1_storeys	
5	TRF_RH1_systems	Closeout Submit	ifcReferen	Submitted	Facility	TRF_RH1	C:\Users\nick\Documents\My Projects\EU Streamer\WP7\models\TRF_RH1_systems_system.ifcxml				n/a	AEC3 UK B ifcDocumen	n/a	TRF_RH1_systems	
6	TRF_RH1_massing	Closeout Submit	ifcReferen	Submitted	Facility	TRF_RH1	C:\Users\nick\Documents\My Projects\EU Streamer\WP7\models\TRF_RH1_massing.ifcxml				n/a	AEC3 UK B ifcDocumen	n/a	TRF_RH1_massing	
7															
Zone Type Component System Assembly Connection Spare Resource Job Impact Document Attribute Coordinate Issue 4															

- Massing
- Departments
- Storey
- Zones and Systems
- Meters

Massing





The Rotherham
NHS Foundation Trust



Sketchup Pro with IFC import/export

Q1 space design tool




Level	Occupied
Courts	TRUE
Courts	TRUE

TRF RH1 description




- Summary report
- Text description
- Manual markup




Out-Patients Department



Ward B6 : Surgical Ward



Ward B6



Identity, placement, relationships and properties

[illegible]

TRF RH1 Systems




- Multiple options
- COBie format
- Existing and possible fabric and MEP system options automatically captured
- Centralised CHP and DHW also documented

	A	B	C	D	E	F	G	H	I
	Name	CreatedBy	CreatedOn	Category	ComponentNames	ExtSystem	ExtObject	ExtIdentifier	Description
1									
2	B6 Ceilings Option 0	nn@aec3.	2015-02-17T10:10:41	Ss_30_25	B6 Ceilings Option 0	General Spreadsheet to IFC converter	IfcSystem	0sys00000	Suspended ceilings with fibre board tiles with metal slatted ceilings to so
3	B6 External Glazing Option 0	nn@aec3.	2015-02-17T10:10:41	Ss_25_60	B6 External Glazing Option	General Spreadsheet to IFC converter	IfcSystem	0sys00000	Full height wooden framed single glazed, bottom two panels opaque, ins
4	B6 External Glazing Option 1	nn@aec3.	2015-02-17T10:10:41	Ss_25_60	B6 External Glazing Option	General Spreadsheet to IFC converter	IfcSystem	0sys00000	Triple glazed units with greater natural light
5	B6 External Glazing Option 2	nn@aec3.	2015-02-17T10:10:41	Ss_25_60	B6 External Glazing Option	General Spreadsheet to IFC converter	IfcSystem	0sys00000	Solar tinted glass or film
6	B6 External Glazing Option 3	nn@aec3.	2015-02-17T10:10:41	Ss_25_50	B6 External Glazing Option	General Spreadsheet to IFC converter	IfcSystem	0sys00000	Solar shading
7	B6 External Walling Option 0	nn@aec3.	2015-02-17T10:10:41	Ss_25_13	B6 External Walling Option	General Spreadsheet to IFC converter	IfcSystem	0sys00000	Traditional masonry brick and block construction
8	B6 Floors Option 0	nn@aec3.	2015-02-17T10:10:41	Ss_30_12	B6 Floors Option 0	General Spreadsheet to IFC converter	IfcSystem	0sys00000	Concrete, screed and lino with Stramit boards installed between the floo
9	B6 Heating Circuits Option 0	nn@aec3.	2015-02-17T10:10:41	Ss_60_40	B6 Heating Circuits Option	General Spreadsheet to IFC converter	IfcSystem	0sys00000	One heating circuit PR3(W) via zone valve 12
10	B6 Heating Controls Option 0	nn@aec3.	2015-02-17T10:10:41	Ss_75_70	B6 Heating Controls Option	General Spreadsheet to IFC converter	IfcSystem	0sys00000	Single temperature sensor heating control for whole zone
11	B6 Heating Controls Option 1	nn@aec3.	2015-02-17T10:10:41	Ss_75_70	B6 Heating Controls Option	General Spreadsheet to IFC converter	IfcSystem	0sys00000	Individual room/area wireless temperature sensor heating controls
12	B6 Heating Option 0	nn@aec3.	2015-02-17T10:10:41	Ss_60_40	B6 Heating Option 0	General Spreadsheet to IFC converter	IfcSystem	0sys00000	Franger heated ceilings with a small proportion of wet heating systems
13	B6 Heating Option 1	nn@aec3.	2015-02-17T10:10:41	Ss_60_40	B6 Heating Option 1	General Spreadsheet to IFC converter	IfcSystem	0sys00000	Underfloor heating system
14	B6 Insulation Option 0	nn@aec3.	2015-02-17T10:10:41	n/a	B6 Insulation Option 0	General Spreadsheet to IFC converter	IfcSystem	0sys00000	25-50mm thick fibre glass insulation to ceilings and mineral insulation to
15	B6 Insulation Option 1	nn@aec3.	2015-02-17T10:10:41	n/a	B6 Insulation Option 1	General Spreadsheet to IFC converter	IfcSystem	0sys00000	100mm thick insulation to ceilings and additional cavity insulation to ext
16	B6 Insulation Option 2	nn@aec3.	2015-02-17T10:10:41	Ss_25_20	B6 Insulation Option 2	General Spreadsheet to IFC converter	IfcSystem	0sys00000	Clad external walls with EWIS (External Wall Insulation System)
17	B6 Internal Partitions Option 0	nn@aec3.	2015-02-17T10:10:41	Ss_25_10	B6 Internal Partitions Optic	General Spreadsheet to IFC converter	IfcSystem	0sys00000	Plasterboard internal walls
18	B6 Lighting Automatic Controls Option 0	nn@aec3.	2015-02-17T10:10:41	Ss_70_80	B6 Lighting Automatic Cont	General Spreadsheet to IFC converter	IfcSystem	0sys00000	No controls
19	B6 Lighting Automatic Controls Option 1	nn@aec3.	2015-02-17T10:10:41	Ss_70_80	B6 Lighting Automatic Cont	General Spreadsheet to IFC converter	IfcSystem	0sys00000	Occupancy sensor control and dimmable options
20	B6 Lighting Option 0	nn@aec3.	2015-02-17T10:10:41	Ss_70_80	B6 Lighting Option 0	General Spreadsheet to IFC converter	IfcSystem	0sys00000	5 foot, 65W, T12 fluorescent, two rooms have 4 x 18W modular fluores
21	B6 Lighting Option 1	nn@aec3.	2015-02-17T10:10:41	Ss_70_80	B6 Lighting Option 1	General Spreadsheet to IFC converter	IfcSystem	0sys00000	LED 600x600mm 40W tile panel lighting and/or High Frequency T5 fluore
22	B6 Mechanical Ventilation Option 0	nn@aec3.	2015-02-17T10:10:41	Ss_65_Vel	B6 Mechanical Ventilation	General Spreadsheet to IFC converter	IfcSystem	0sys00000	Some mechanical ventilation but supply only with no energy recovery

Fabric and MEP systems

- including Options



Metering




$$\text{AnnualEstimate} = 365 * (\text{EndReading} - \text{StartReading}) / (\text{EndDate} - \text{StartDate})$$


Description	Name	Type	Zone	Fuel and Uni	ElectricityAnnualEstimate	GasAnnualEstimate	HeatAnnualEstimate
Audiology V16 Heat Meter	V16	Heat Meter	Audiology	Heat kWh			0.025
Audiology V17 Heat Meter	V17	Heat Meter	Audiology	Heat kWh			40.200
Audiology V18 Heat Meter	V18	Heat Meter	Audiology	Heat kWh			5.810
Audiology V19 Heat Meter	V19	Heat Meter	Audiology	Heat kWh			1.390
Estates Admin EB24 Panel	EB24	Panel	Estates Admin	Electricity kWh	15577		
Eye Clinic EC7A Panel	EC7A	Panel	Eye Clinic	Electricity kWh	42317		
Eye Clinic EC7B Panel	EC7B	Panel	Eye Clinic	Electricity kWh	38077		
Eye Clinic V22 riser Heat Meter	V22 riser	Heat Meter	Eye Clinic	Heat kWh			1.515

Description	Name	Meter Type	Zone	Fuel and Uni	ElectricityAnnualEstimate	GasAnnualEstimate	HeatAnnualEstimate
Ward B6 B40 Panel	B40	Panel	Ward B6	Electricity kWh	9526		
Ward B6 B6 Heat Meter Heat Meter	B6 Heat Meter	Heat Meter	Ward B6	Heat kWh			111.983
Ward B6 EB40 Panel	EB40	Panel	Ward B6	Electricity kWh	20117		
Oral maxillo EC6 Panel	EC6	Panel	Oral maxillo	Electricity kWh	8214		
Reception A EC8A Panel	EC8A	Panel	Reception A	Electricity kWh	22250		
Reception A EC8B Panel	EC8B	Panel	Reception A	Electricity kWh	17935		
Reception A V20 top Heat Meter	V20 top	Heat Meter	Reception A	Heat kWh			0.298
Reception A V21 bottom Heat Meter	V21 bottom	Heat Meter	Reception A	Heat kWh			0.149
Reception D EC9A Panel	EC9A	Panel	Reception D	Electricity kWh	41747		
Reception D EC9B Panel	EC9B	Panel	Reception D	Electricity kWh	34836		
Theatre 9 EB34 Panel	EB34	Panel	Theatre 9	Electricity kWh	33364		
Theatre 9 T9 Main Main	T9 Main	Main	Theatre 9	Electricity kWh	123478		
Theatre 9 T9 MCC Panel	T9 MCC	Panel	Theatre 9	Electricity kWh	65169		
Theatre 9 T9 Total Panel Total	T9 Total	Panel Total	Theatre 9	Electricity kWh	113061		
Theatre 9 T9 UPS Panel	T9 UPS	Panel	Theatre 9	Electricity kWh	14529		
Ward A7 A32 Panel	A32	Panel	Ward A7	Electricity kWh	12107		
Ward A7 A7 Total Panel Total	A7 Total	Panel Total	Ward A7	Electricity kWh	52083		
Ward A7 EA32 Panel	EA32	Panel	Ward A7	Electricity kWh	11475		
Ward A7 EA33 Panel	EA33	Panel	Ward A7	Electricity kWh	28501		
Ward B6 B40 Panel	B40	Panel	Ward B6	Electricity kWh	9526		
Ward B6 B6 Heat Meter Heat Meter	B6 Heat Meter	Heat Meter	Ward B6	Heat kWh			111.983

Metering



Sub-circuit monitoring




Power consumption

1003 W: Maximum— Highest daily rate

541 W: Average

201 W: Minimum – Lowest daily rate




Model requirements checking

- Xbim Xplorer



Asset Information Model



Rotherham Hospital

CHOOSING AN UPGRADE STRATEGY

SPEAKER: NICK NISBET



IMPLEMENTERS WORKSHOP 1, SESSION 7

The Rotherham
NHS Foundation Trust



Streamer

European research on energy-efficient healthcare districts

www.aec3.eu



AEC3 Ltd.



AEC3 . BIM experts for over ten years !

www.aec3.eu

EU STREAMER



The Rotherham **NHS**
NHS Foundation Trust

Rotherham Hospital Challenge

The challenge is to determine the most cost effective options for key fabric/systems upgrades to specific departments of Rotherham Hospital to achieve the best payback over a 10 year period.

Workshop :

- Rotherham Hospital Proposal

© 2016 AEC3 UK Limited. nn@aec3.com

Streamer

The Rotherham Hospital NHS Foundation Trust (TRF) Workshop

Please enter your Workshop Team/Table Name:

Workshop Team: _____
 Team/Table name: _____
 Table1

Please enter your Workshop Team/Table Member Names and Organisations:

Team Members: _____

Name:	<input type="text" value="Bob Wakelam"/>	Email:	<input type="text" value="bw@aec3.com"/>
Name:	<input type="text" value="Nick Nisbet"/>	Email:	<input type="text" value="nn@aec3.com"/>
Name:	<input type="text"/>	Email:	<input type="text"/>
Name:	<input type="text"/>	Email:	<input type="text"/>
Name:	<input type="text"/>	Email:	<input type="text"/>
Name:	<input type="text"/>	Email:	<input type="text"/>
Name:	<input type="text"/>	Email:	<input type="text"/>
Name:	<input type="text"/>	Email:	<input type="text"/>
Name:	<input type="text"/>	Email:	<input type="text"/>
Name:	<input type="text"/>	Email:	<input type="text"/>

OPC



Streamer Proposal: **OPC - Heating**

Options:

- ☒ Frenger heated ceilings with a small proportion of wet heating systems
- ☐ Underfloor heating system

Streamer Proposal: **OPC - Heating Controls**

Options:

- ☒ Single temperature sensor heating control for whole zone
- ☐ Individual room/area wireless temperature sensor heating controls

Streamer Proposal: **OPC - Lighting**

Options:

- ☒ Twin 6 foot 65W fluorescent T8, 4 x 18W modular fluorescent fittings and 38W 2 D fittings
- ☐ LED 600x600mm 40W tile panel lighting and/or High Frequency T5 fluorescent fittings

Streamer Proposal: **OPC - Lighting Automatic Controls**

Options:

- ☒ No controls
- ☐ Occupancy sensor control and dimmable options

Streamer Proposal: **OPC - External Glazing**

Options:

- ☒ Full height uPVC double glazed, bottom two panels opaque, insulated and blockwork to cill
- ☐ Triple glazed units with greater natural light
- ☐ Solar tinted glass or film
- ☐ Solar shading

Streamer Proposal: **OPC - Insulation**

Options:

- ☒ 25-50mm thick fibre glass insulation to ceilings and mineral insulation to external walls
- ☐ 100mm thick insulation to ceilings and additional cavity insulation to external walls
- ☐ Clad external walls with EWIS (External Wall Insulation System)

Rotherham Hospital

EVALUATION: HAVE WE FOUND A GOOD STRATEGY?

SPEAKER: NICK NISBET



IMPLEMENTERS WORKSHOP 1, SESSION 10

The Rotherham
NHS Foundation Trust



Streamer 
European research on energy-efficient healthcare districts

Result page



RH1 Refurbishment



EU STREAMER REPORT



Project : RH1 Project

Date : 2016-06-08T12:06:08

Prepared by : AEC3 UK Ltd

rdash-OPCLT1-OPCEG1-OPCIN1-WB6HT1-WB6HC1-WB6LT1-WB6LC1-WB6EG1-WB6IN1

Results				
Name	Description	Value	Unit	
Project	RH1 Project	RH1 Refurbishment		
Phase	Option	rdash-OPCLT1-OPCEG1-OPCIN1-WB6HT1-WB6HC1-WB6LT1-WB6LC1-WB6EG1-WB6IN1		
Name	Description	Value	Unit	
Site	RH1 Site	Rotherham Hospital, Moorfield Road, Rotherham, RH1 9QX		
Name	Description	Value	Unit	
Building	RH1 building	Rotherham Hospital		
GrossAreaPlanned	GrossAreaPlanned	1123.00	m2	
AnnualEnergyDemand	Energy demand	1603154.37	MJ	
AnnualEnergyConsumption	Energy consumption	1183493.76	MJ	
Capital Cost	Capital Cost	147954.75	£	
Heating energy demand	Heating energy demand	675609.15	MJ	
Auxiliary energy demand	Auxiliary energy demand	138790.45	MJ	
Lighting energy demand	Lighting energy demand	33003.85	MJ	
Hot water energy demand	Hot water energy demand	336094.81	MJ	
Equipment energy demand	Equipment energy demand	419656.12	MJ	
Natural gas energy consumption	Natural gas energy consumption	1011699.47	MJ	
Grid Supply Electricity energy consumptions	Grid Supply Electricity energy consumptions	171794.29	MJ	
Name	Description	Value	Unit	
Zone	OPC	OPC		
BouwcollegeLayer	Four way classification of hospital spaces by activity	O		
AccessSecurity	Accessibility	A2		
Construction	Construction complexity	C1 C1 : Office level Concrete and Screed Suspended Grid		
Equipment	Equipment density	EQ5 EQ5 : Office level and medical gases, extra electrical power and extra ICT data point		
HygieneClass	HygieneClass	H3		
UserProfile	Usage profile	U1		
GrossAreaPlanned	GrossAreaPlanned	500.00	m2	
Internal Gains from Persons	Internal Gains from Persons	109236.00	MJ	
Internal Gains from Appliances	Internal Gains from Appliances	242072.00	MJ	
Internal Gains from Lighting	Internal Gains from Lighting	1379.70	MJ	
Internal Gains Total	Internal Gains Total	352688.00	MJ	
Name	Description	Value	Unit	
Zone	Ward-B6	Ward B6		

Workshop 1: UK NCM SBEM Simulation results




BaseCase

Projectteam

FTRealConstruction

WWright

rdash



Workshop 1 Simulation results




Team	Proposal	Energy MJ Saving	Cost	MJ/£
BaseCase	-	0.00	0.00	0.00
Project team	OPCHC1-OPCLT1-OPCLC1-OPCEG3-OPCIN1—WB6HC1-WB6LT1-WB6LC1-WB6EG1-WB6IN1	102731.00	126736.75	0.81
WWright	OPCHC1-OPCLT1-OPCLC1-OPCEG2-OPCIN1—WB6HC1-WB6LT1-WB6LC1-WB6EG1-WB6IN1	109394.88	120664.75	0.91
FTReal Construction	OPCHC1-OPCLT1-OPCLC1-OPCEG2-OPCIN2—WB6HC1-WB6LT1--WB6EG1-WB6IN2	125996.75	114473.50	1.10
rdash	OPCLT1-OPCEG1-OPCIN1-WB6HT1-WB6HC1-WB6LT1-WB6LC1-WB6EG1-WB6IN1	255430.81	147954.75	1.73



Interactive graphing of results

Option		Saving (MJ)	Cost (£)	Saving/Cost (MJ/£)	Payback at 1p/M	Payback at 8p/M
BaseCase	-	0.00	0.00	0.00		
Projectteam	OPCHC1-OPCLT1-OPCLC1-OPCEG3-OPCIN1--WB6HC1-WB6LT1-WB6LC1-WB6EG1-WB6IN1	102731.00	126736.75	0.81	123	15
WWright	OPCHC1-OPCLT1-OPCLC1-OPCEG2-OPCIN1--WB6HC1-WB6LT1-WB6LC1-WB6EG1-WB6IN1	109394.88	120664.75	0.91	110	14
FTRealConstr	OPCHC1-OPCLT1-OPCLC1-OPCEG2-OPCIN2--WB6HC1-WB6LT1--WB6EG1-WB6IN2	125996.75	114473.50	1.10	91	11
rdash	OPCLT1-OPCEG1-OPCIN1-WB6HT1-WB6HC1-WB6LT1-WB6LC1-WB6EG1-WB6IN1	255430.81	147954.75	1.73	58	7

Saving vs Expenditure



- The team that chose the fewest options, but spent the most, saved double the energy savings of the others and achieved the best pay-back.



BSRIA benchmarks for general hospitals		W/m ²
Electricity		10.3
Small power		25.0
Heating		80.1

Table 3: Energy benchmarks based on BSRIA [10] Blue Book 2017

Rotherham Hospital		W/m ²
Electricity from supplier		1.9
Renewable electricity		0.3
On-site electricity generation		13.8
Total electrical energy consumed		16.0
Natural gas for heating		19.9
Natural gas for CHP		38.8
Natural gas for process use (cooking, labs, etc)		0.4
Primary fossil energy		59.2
Thermal energy utilised from CHP		1.2
Total thermal energy consumed		21.0
Energy need		74.6

Table 4: Energy metrics published by TRFT (2017)

	W/m ²	Published	SBEM	Metered
Electricity Power Consumption 2007		17.5	34.7	
Gas Power Consumption 2007		53.3	24.9	
Electricity Power Consumption 2015		2.4		
Gas Power Consumption 2015		66.1		
Power Consumption			59.5	
Heating power demand (gas)			17.9	
Auxiliary power demand (electricity)			3.8	
Lighting power demand (electricity)			19.0	5.9
Hot water power demand (gas)			6.9	
Equipment power demand (electricity)			11.8	3.0

Table 5: Energy metric published by TRFT, predicted for two departments by SBEM and monitored

RDaSH proposal package		Delta W/m ²
Heating power demand (gas)		-25.0
Lighting power demand (electricity)		+2.3

Table 6: Change in RDaSH [11] power demand density from an example upgrade proposal

- Strong methodology
 - Merging of existing data sources
 - Use of simple labelling
 - Automated energy modelling
 - Collaborative gaming
- Weakness of energy simulation tool
 - CHP
 - Heating controls
 - Known loads and activities
- Opportunity
 - ‘Gaming’ and ‘Learning’
 - Online self assessment
 - Mixed modelling tools
- Threats
 - Over modelling
 - Confusion of comparative and absolute predictions

Colophon

PowerPoint: Rotherham Implementers Workshop 1

Issue Date:

Author:

Version:

The Streamer project is co-financed by the European Commission under the seventh research framework programme with contract no.: 608739. The information in this publication does not necessarily represent the view of the European Commission.

© **Streamer**

All rights reserved. Any duplication or use of objects such as diagrams in other electronic or printed publications is not permitted without the author's agreement.



**Thank you
Any questions?**

Nick Nisbet



nn@aec3.com

