

BUILDING DT TRUSTWORTHINESS

"Privacy Metrics Tool for Building Digital Twins Trustworthiness"

SEP. 8TH, 2022 @10.45 AM CEST | NICE, FRANCE



BUILDING DIGITAL TWIN
ASSOCIATION 



SPHERE
BIM DIGITAL TWIN PLATFORM




**SUSTAINABLE
PLACES 2022**

Session Chair: Eduard Loscos, BDTA (Building Digital Twin Association) – president@buildingdigitaltwin.org

Pablo Vicente Legazpi / BDTA – p.Legazpi@buildingdigitaltwin.org – PRESENTER

Andre van Delft / DEMO CONSULTANTS - Andre@demobv.nl



SUSTAINABLE
PLACES

CONTENTS

- Workshop video BDTIC May2022: <https://youtu.be/phnj7QYpTUE>
- Presenters
- Introduction:
 - Other EU projects with pilots: we can help you. We can collaborate
 - Legislation needs standards, objective tools
 - EXAMPLE tno demo pilot



SUSTAINABLE
PLACES

SPHERE DEMO PILOT TNO PRIVACY EXAMPLE

TNO SPHERE PILOT MEASURED PARAMETERS

Portal Klimaatgarant

Filename	Description	Interval	ENTITIES	MAGNITUDES	STATISTICS	SAMPLING FREQ.	DATA USE	DATA CONTROL	TOTAL	
W.._Energy_use_HP_and_fan_kWh.csv	kWh-meter for heat pump and balanced ventilation	Daily	HOME	0.500 KWH	0.500 MEAN	0.100 DAY	0.050 CLOUD	0.001 CLOUD	0.001 CLOUD	1250
W.._Energy_prod_PV_kWh.csv	kWh-meter PV-production	Daily	HOME	0.500 PV PROD	0.010 MEAN	0.100 DAY	0.050 CLOUD	0.001 CLOUD	0.001 CLOUD	25
W.._Energy_use_HP_cooling_kWh.csv	kWh-meter cooling heat pump	Daily	EQUIPMENT	0.500 KWH	0.500 MEAN	0.100 DAY	0.050 CLOUD	0.001 CLOUD	0.001 CLOUD	1250
W.._Energy_use_HP_heating_kWh.csv	kWh-meter heating heat pump	Daily	EQUIPMENT	0.500 KWH	0.500 MEAN	0.100 DAY	0.050 CLOUD	0.001 CLOUD	0.001 CLOUD	1250
W.._Energy_use_HP_DHW_kWh.csv	kWh-meter domestic hot water preparation heat pump	Daily	EQUIPMENT	0.500 KWH	0.500 MEAN	0.100 DAY	0.050 CLOUD	0.001 CLOUD	0.001 CLOUD	1250
W.._Energy_use_HP_standby_kWh.csv	kWh-meter standby heat pump	Daily	EQUIPMENT	0.500 KWH	0.500 MEAN	0.100 DAY	0.050 CLOUD	0.001 CLOUD	0.001 CLOUD	1250
W.._Outside_temperature_C.csv	Outside temperature	Hour	ENVIRONMENT	0.001 TEMP	0.500 MEAN	0.100 HOUR	0.100 CLOUD	0.001 CLOUD	0.001 CLOUD	5
W.._Temp_livingroom_C.csv	Temperature livingroom	Hour	ROOM	1.000 TEMP	0.500 MEAN	0.100 HOUR	0.100 CLOUD	0.001 CLOUD	0.001 CLOUD	5000
W.._Setpoint_livingroom_C.csv	Setpoint livingroom	Hour	ROOM	1.000 TEMP	0.500 MEAN	0.100 HOUR	0.100 CLOUD	0.001 CLOUD	0.001 CLOUD	5000
W.._Energy_use_Eheater_Amp.csv	Ampere used for electric room heating	Hour	EQUIPMENT	0.500 AMP	0.500 MEAN	0.100 HOUR	0.100 CLOUD	0.001 CLOUD	0.001 CLOUD	2500
W.._Use_Eheater_perc_per_day.csv	Percentage use per day for electric room heating	Daily	ROOM	1.000 PU	0.010 MEAN	0.100 DAY	0.050 CLOUD	0.001 CLOUD	0.001 CLOUD	50

Portal Smart energy meter

Filename	Description	Interval	ENTITIES	MAGNITUDES	STATISTICS	SAMPLING FREQ.	DATA USE	DATA CONTROL	TOTAL	
W.._EnergyUse_SmartMeter_kWh.csv	Energy use registered by smart energy meter	15MIN	HOME	0.500 KWH	0.500 MEAN	0.100 15MIN	0.500 CLOUD	0.001 CLOUD	0.001 CLOUD	12500
W.._EnergyDelivered_SmartMeter_kWh.csv	Energy delivered registered by smart energy meter	15MIN	HOME	0.500 KWH	0.500 MEAN	0.100 15MIN	0.500 CLOUD	0.001 CLOUD	0.001 CLOUD	12500

Portal Flair balanced ventilation system

Filename	Description	Interval	ENTITIES	MAGNITUDES	STATISTICS	SAMPLING FREQ.	DATA USE	DATA CONTROL	TOTAL	
W.._Fan_position_[-].csv	Position of the fan (supply and exhaust): 1 (minimum), 2, 3, 4 (maximum)	15MIN	EQUIPMENT	0.500 PC	0.5 MEAN	0.100 15MIN	0.500 CLOUD	0.001 CLOUD	0.001 CLOUD	12500
W.._supply_[m3 per h].csv	Supply flow in m ³ /h	15MIN	EQUIPMENT	0.500 AF	0.1 MEAN	0.100 15MIN	0.500 CLOUD	0.001 CLOUD	0.001 CLOUD	2500
W.._exhaust_[m3 per h].csv	Exhaust flow in m ³ /h	15MIN	EQUIPMENT	0.500 AF	0.1 MEAN	0.100 15MIN	0.500 CLOUD	0.001 CLOUD	0.001 CLOUD	2500
W.._pressure_supply_[Pa].csv	Supply pressure in Pa	15MIN	EQUIPMENT	0.500 PRES	0.1 MEAN	0.100 15MIN	0.500 CLOUD	0.001 CLOUD	0.001 CLOUD	2500
W.._pressure_exhaust_[Pa].csv	Exhaust pressure in Pa	15MIN	EQUIPMENT	0.500 PRES	0.1 MEAN	0.100 15MIN	0.500 CLOUD	0.001 CLOUD	0.001 CLOUD	2500

TNO SPHERE PILOT MEASURED PARAMETERS

Portal Klimaatgarant

Filename	Description	Interval	ENTITIES	MAGNITUDES	STATISTICS	SAMPLING FREQ.	DATA USE	DATA CONTROL	TOTAL	
W.._Energy_use_HP_and_fan_kWh.csv	kWh-meter for heat pump and balanced ventilation	Daily	HOME	0.500 KWH	0.500	MEAN	0.100 DAY	0.050 CLOUD	0.001 INDIV.CONTR 1.000	1.25
W.._Energy_prod_PV_kWh.csv	kWh-meter PV-production	Daily	HOME	0.500 PV PROD	0.010	MEAN	0.100 DAY	0.050 CLOUD	0.001 INDIV.CONTR 1.000	0.025
W.._Energy_use_HP_cooling_kWh.csv	kWh-meter cooling heat pump	Daily	EQUIPMENT	0.500 KWH	0.500	MEAN	0.100 DAY	0.050 CLOUD	0.001 INDIV.CONTR 1.000	1.25
W.._Energy_use_HP_heating_kWh.csv	kWh-meter heating heat pump	Daily	EQUIPMENT	0.500 KWH	0.500	MEAN	0.100 DAY	0.050 CLOUD	0.001 INDIV.CONTR 1.000	1.25
W.._Energy_use_HP_DHW_kWh.csv	kWh-meter domestic hot water preparation heat pump	Daily	EQUIPMENT	0.500 KWH	0.500	MEAN	0.100 DAY	0.050 CLOUD	0.001 INDIV.CONTR 1.000	1.25
W.._Energy_use_HP_standby_kWh.csv	kWh-meter standby heat pump	Daily	EQUIPMENT	0.500 KWH	0.500	MEAN	0.100 DAY	0.050 CLOUD	0.001 INDIV.CONTR 1.000	1.25
W.._Outside_temperature_C.csv	Outside temperature	Hour	ENVIRONMENT	0.001 TEMP	0.500	MEAN	0.100 HOUR	0.100 CLOUD	0.001 INDIV.CONTR 1.000	0.005
W.._Temp_livingroom_C.csv	Temperature livingroom	Hour	ROOM	1.000 TEMP	0.500	MEAN	0.100 HOUR	0.100 CLOUD	0.001 INDIV.CONTR 1.000	5
W.._Setpoint_livingroom_C.csv	Setpoint livingroom	Hour	ROOM	1.000 TEMP	0.500	MEAN	0.100 HOUR	0.100 CLOUD	0.001 INDIV.CONTR 1.000	5
W.._Energy_use_Eheater_Amp.csv	Ampere used for electric room heating	Hour	EQUIPMENT	0.500 AMP	0.500	MEAN	0.100 HOUR	0.100 CLOUD	0.001 INDIV.CONTR 1.000	2.5
W.._Use_Eheater_perc_per_day.csv	Percentage use per day for electric room heating	Daily	ROOM	1.000 PU	0.010	MEAN	0.100 DAY	0.050 CLOUD	0.001 INDIV.CONTR 1.000	0.05

Portal Smart energy meter

Filename	Description	Interval	ENTITIES	MAGNITUDES	STATISTICS	SAMPLING FREQ.	DATA USE	DATA CONTROL	TOTAL	
W.._EnergyUse_SmartMeter_kWh.csv	Energy use registered by smart energy meter	15MIN	HOME	0.500 KWH	0.500	MEAN	0.100 15MIN	0.500 CLOUD	0.001 INDIV.CONTR 1.000	12.5
W.._EnergyDeliverd_SmartMeter_kWh.csv	Energy deliver registered by smart energy meter	15MIN	HOME	0.500 KWH	0.500	MEAN	0.100 15MIN	0.500 CLOUD	0.001 INDIV.CONTR 1.000	12.5

Portal Flair balanced ventilation system

Filename	Description	Interval	ENTITIES	MAGNITUDES	STATISTICS	SAMPLING FREQ.	DATA USE	DATA CONTROL	TOTAL	
W.._Fan_position_[-].csv	Position of the fan (supply and exhaust): 1 (minimum), 2, 3, 4 (maximum)	15MIN	EQUIPMENT	0.500 PC	0.5	MEAN	0.100 15MIN	0.500 CLOUD	0.001 INDIV.CONTR 1.000	12.5
W.._supply_[m3 per h].csv	Supply flow in m ³ /h	15MIN	EQUIPMENT	0.500 AF	0.1	MEAN	0.100 15MIN	0.500 CLOUD	0.001 INDIV.CONTR 1.000	2.5
W.._exhaust_[m3 per h].csv	Exhaust flow in m ³ /h	15MIN	EQUIPMENT	0.500 AF	0.1	MEAN	0.100 15MIN	0.500 CLOUD	0.001 INDIV.CONTR 1.000	2.5
W.._pressure_supply_[Pa].csv	Supply pressure in Pa	15MIN	EQUIPMENT	0.500 PRES	0.1	MEAN	0.100 15MIN	0.500 CLOUD	0.001 INDIV.CONTR 1.000	2.5
W.._pressure_exhaust_[Pa].csv	Exhaust pressure in Pa	15MIN	EQUIPMENT	0.500 PRES	0.1	MEAN	0.100 15MIN	0.500 CLOUD	0.001 INDIV.CONTR 1.000	2.5
W.._bypass_(1=opening,2=closing,3=open,4=closed)_[-].csv	Bypass valve for the heat recovery	15MIN	EQUIPMENT	0.500 PC	0.5	MEAN	0.100 15MIN	0.500 CLOUD	0.001 INDIV.CONTR 1.000	12.5
W.._frost_control_(2=off,7=heaterON)_[-].csv	Mode of the frost protection: 2= frost protection off, 7= electric heater on	15MIN	EQUIPMENT	0.500 PC	0.5	MEAN	0.100 15MIN	0.500 CLOUD	0.001 INDIV.CONTR 1.000	12.5
W.._power_heater_[%].csv	Power of the electric heater in case of frost protection	15MIN	EQUIPMENT	0.500 KWH	0.5	MEAN	0.100 15MIN	0.500 CLOUD	0.001 INDIV.CONTR 1.000	12.5
W.._temp_from_outside_[C].csv	Temperature from outside before the heat recovery unit	15MIN	EQUIPMENT	0.500 TEMP	0.5	MEAN	0.100 15MIN	0.500 CLOUD	0.001 INDIV.CONTR 1.000	12.5



SUSTAINABLE
PLACES

A.(Andre) van Delft, MSc / Director



Privacy problems and solutions in EU project BIMSPEED